

# **Compliance Statement**

No. 2025-116

## Data communication cable, Category 6A

#### Company

CobiCabling Sp. z o.o. ul. Austriacka 4 64-140 Leszno Poland

### **Product description**

Unscreened cable (U/UTP) characterised up to 500 MHz Horizontal floor wiring cable, 100  $\Omega$  4 twisted pairs Flame retardant, halogen free

#### **Product identification**

C13-1xxx CobiCabling CAT 6A U/UTP LSOH/LSFRZH Dca/B2ca

#### Generic cabling and cabling components standards - Category 6A cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-11-1:2012
- TIA-568.2-D:2018

including all cable alien crosstalk parameters (PS ANEXT and PS AACR-F)

## Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

**Technical report** 12522832, DANAK-19/24842

**EC Cabling product ID** 

1 March 2026

**CS** valid until

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 25 February 2025

Lars Lindskov Pedersen

Test Manager

Dennis Andersen Head of Department

