

2658-CPR-5015_FAM095_05

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Data Transmission Cable CAT6/6A/7/7A/8 F/FTP LS0H/LSFR0H - Cables for general application in construction works subject to reaction to fire requirements (see family range in appendix)

Placed on the market by

CobiCabling Sp. z o.o.

Austriacka 4

64-100 Leszno – Poland

And produced in the manufacturing plant

5015

This certificate attests that all provisions concerning the assessment and verification of constancy of performances detailed in annex ZZ of the standard


EN 50575:2014 + A1:2016

Under system 1+ for the performances set out here below are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

Level of class of performance: B2_{ca}-s1a,d0,a1


This certificate was first issued on 2019/06/20 and will remain valid as long as the test methods and/or factory production control requirements included harmonized standard, used to assess the performance of the declared essential characteristic, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

Brussels, 2025/02/19



C. LANA

Certification Manager



FAM095_05				
Cable type	Brand name	Cable description	Product ref.	Number of conductors
Cat6/6A/7/7A/8 F/FTP LS0H/LSFR0H B2ca	CobiCabling	4x[2x(BC+PE) + Al-Foil shield]+Drain Wire + AL-Foil shield + LS0H/LSFR0H	C23-xxxx	8 (4 Pair)
XXXX: packaging length				

The test results are laid down in certification file ref.630309/22_05

This certificate is based on test reports ref. AJFS2110009010FF-01, AJFS2110009010FF-02, AJFS2110009010FF-03, AJFS2110009010FF-04 and classification report 630309.22_05_Class

Modification:

February 2025: replacement of LSZH by LS0H/LSFR0H