

Service key for electronic module (Part No. 80490x)



Part-No.: 769916

With this metal service key, the test functionality of the manual call point is activated and reset by authorized persons only. The key is suitable for all electronic modules with Part No. 80490x from index 05 and yellow locking.

Common technical data

Phone: +49 2131 40615 600

Faximile: +49 2131 40615 606

Subject to change without noticel © 2022 Honeywell International Inc.